



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 2, 2009

RE: AURORA CENTRAL WWTP
NPDES #3PC00016

Mr. John Trew
City of Aurora
Brown-Keidel Service Center
158 West Pioneer Trail
Aurora, Ohio 44202

Dear Mr. Trew:

This letter will document a January 30, 2009 compliance inspection at the Aurora Central WWTP.

A review of monthly operating reports for the time period September 2007 through November 2008 indicated the following permit violations based on computer screening of the data:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2008	Mercury, Total	30D Conc	1.3	2.9	2/1/2008
February 2008	Mercury, Total	30D Qty	0.000008	.00001	2/1/2008
June 2008	Mercury, Total	30D Conc	1.3	6.6	6/1/2008
June 2008	Mercury, Total	30D Qty	0.000008	.00002	6/1/2008
October 2007	Mercury, Total	30D Conc	1.3	2.4	10/1/2007
May 2008	Phosphorus, Total (P)	30D Conc	0.87	.905	5/1/2008
May 2008	Mercury, Total	30D Conc	1.3	2.5	5/1/2008
April 2008	Mercury, Total	30D Conc	1.3	2.	4/1/2008

The plant appeared well run and operated and was producing a clear effluent at the time of my inspection.

Should you have any questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Scientist
Division of Surface Water

WJZ/mt

cc: Andy Krispinski, City of Aurora