



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 9, 2011

RE: AURORA CENTRAL WWTP
NPDES #3PC00016

Mr. John Trew
City of Aurora
Brown-Keidel Service Center
158 West Pioneer Trail
Aurora, Ohio 44202

Dear Mr. Trew:

This letter will document a May 27, 2011 compliance inspection at the Aurora Central WWTP.

A review of monthly operating reports for the time period January 2009 through April 2011 indicated the following permit violations based on computer screening of the data:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2009	Mercury	30D Conc.	1.3	2.33	9/1/2009
May 2009	Phosphorus	30D Conc.	0.87	.94	5/1/2009
February 2009	Phosphorus	30D Conc.	0.9	.91	2/1/2009
December 2010	Chronic Toxicity, <i>C. dubia</i>	1D Conc.	1.21	1.69	12/7/2010
December 2010	Chronic Toxicity, <i>C. dubia</i>	30D Conc.	1.13	1.69	12/1/2010
September 2010	Phosphorus	30D Conc.	0.87	1.28	9/1/2010
September 2010	Phosphorus	7D Conc.	1.3	1.31	9/1/2010
September 2010	Phosphorus	7D Conc.	1.3	1.32	9/15/2010
October 2010	Phosphorus	30D Conc.	0.87	0.94	10/1/2010
June 2009	Phosphorus	7D Qty.	7.39	9.30	6/1/2009

Sludge color in the oxidation ditch was good. Effluent weirs in the secondary clarifiers were clean and flow evenly distributed. UV disinfection was in place and operational.

The plant appeared well run and operated and was producing a clear effluent at the time of my inspection.

A renewal permit is currently being drafted at the district office.

Should you have any questions please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Supervisor
Division of Surface Water

WJZ/mt

pc: Andy Krispinski, City of Aurora