



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 21, 2008

RE: AURORA WESTERLY WWTP  
NPDES #3PD00046

Mr. John Trew  
City of Aurora  
Brown-Keidel Service Center  
158 West Pioneer Trail  
Aurora, Ohio 44202

Dear Mr. Trew:

A review of monthly operating reports for the time period September 2007 through May 2008 indicated the following permit violations based on computer screening of the data:

Effluent Limit Violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2007	Mercury, Total	30D Conc	1.4	2.6	12/1/2007
December 2007	Mercury, Total	30D Qty	0.0000	.00001	12/1/2007
January 2008	Mercury, Total	30D Conc	1.4	3.9	1/1/2008
January 2008	Mercury, Total	30D Qty	0.0000	.00003	1/1/2008
April 2008	Mercury, Total	30D Conc	1.4	1.8	4/1/2008
April 2008	Mercury, Total	30D Qty	0.0000	.00001	4/1/2008
May 2008	Mercury, Total	30D Conc	1.4	1.5	5/1/2008

Should you have any questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski  
Environmental Scientist  
Division of Surface Water

WJZ/mt

cc: Andy Krispinski, City of Aurora, WWTP Superintendent