



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 2, 2009

RE: AURORA WESTERLY WWTP  
NPDES #3PD00046

Mr. John Trew  
City of Aurora  
Brown-Keidel Service Center  
158 West Pioneer Trail  
Aurora, Ohio 44202

Dear Mr. Trew:

This letter will document a January 30, 2009 compliance inspection at the Aurora Westerly WWTP.

A review of monthly operating reports for the time period June 2008 through December 2008 indicated the following permit violations based on computer screening of the data:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2008	Mercury, Total (Low Level)	30D Conc	1.4	5.8	6/1/2008
June 2008	Mercury, Total (Low Level)	30D Qty	0.000007	.00002	6/1/2008

The plant appeared well run and operated and was producing a clear effluent at the time of my inspection.

The facility's renewal NPDES permit was issued as a draft action on December 19, 2008. It is anticipated that it will be issued final in February 2009.

Should you have any questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski  
Environmental Scientist  
Division of Surface Water

WJZ/mt

cc: Andy Krispinski, City of Aurora  
Dan Spradlin, City of Aurora