



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 31, 2009

Marin Brigner
226 Hansberger Avenue
Baltimore, OH 43105

Re: Cornerstone Estates / Fairfield County

Dear Mr. Brigner:

This letter is written regarding the storm water inspection that I conducted at Cornerstone Estates, located in Baltimore, Ohio, on August 26, 2009. I understand that construction activities are currently covered under the General Storm Water Permit. Please be aware that the following issues must be addressed prior to construction activity:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne CDO/DSW

GS/nm Cornerstone Estates, August 26, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



