



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

W. Zarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 28, 2009

Mark Girard  
McKee Door Sales  
3025 Noe-Bixby Road  
Columbus, OH 43232

**Re: McKee Door Sales / Franklin County**

Dear Mr. Girard:

This letter is written regarding the storm water inspection I conducted, on August 24, 2009, of the construction activities at your property located at 4200 Hamilton Square Boulevard. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

**Sediment and Erosion Controls:**

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosures


c: Jeff Bohne, DSW/CDO

GLS/nsm McKee Door Sales, August 24, 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director



**McKee Door Sales  
Blacklick Creek Watershed  
April 15, 2008  
Photo by: Greg Sanders**



**McKee Door Sales  
Blacklick Creek Watershed  
April 15, 2008  
Photo by: Greg Sanders**



