



4GC0265320090806

2009/08/06

4GC02653

PRIMROSE SCHOOL



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 27, 2009

Gray Greiner
Primrose School Franchising Co.
3660 Cedarcrest Road
Acworth, GA 30101

**Re: Storm Water Inspection at Primrose School
Permit # 4Gc02653*AG**

Dear Mr. Greiner:

This letter is written in follow-up to a construction storm water inspection by Sean Tyler of the Ohio EPA, at Primrose School located at Lamplighter Drive east of Buckeye Parkway in Grove City Ohio on August 17, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The perimeter silt fence along the eastern side of the site has failed and will require maintenance at this time.
- The inlets within the site do not have adequate protection at this time (See Figure 1 and 2). Please install the proper protection devices and ensure they are working as intended or demonstrate an approvable alternative
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

21 Day Rule:

Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Gray Greiner
Primrose School Franchising Co.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Primrose School 8-17-09




Figure 1



Figure 2

