



4GC0291120090827

2009/08/27

4GC02911

ORANGE ROAD BRIDGE OVER OLENTANGY RIVER
PRO DEL-T-



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 27, 2009

Ryan J. Mraz
Delaware County Engineer
50 Channing Street
Delaware, OH 43015

Re: Storm Water Inspection at Orange Road Bridge Construction Project

Dear Mr. Mraz:

This letter is written in follow-up to a construction storm water inspection I conducted at the Orange Road Bridge construction project located at the Olentangy River and Orange Road on July 28, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls

- The majority of the barren areas have been adequately protected from erosion with the exception of the northwest and southeast quadrants. Please ensure erosion protection measures are implemented within three (3) days from receipt of this letter for all barren areas associated with this site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.


Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Orange Road Bridge July 28, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



3023 Alkire Road
Scioto River Watershed
Photo By: Rachelle Hows
08/11/09




Figure 1 Construction Activities at Rear of Residential Property

