



4GC0270920090820

2009/08/20

4GC02709

STRIKE CITY



State of Ohio Environmental Protection Agency

RECEIVED ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 20, 2009

Craig Van Bremen
Berry and Miller Construction
42 Hill Road South
Pickerington, OH 43147

Re: Storm Water Inspection at Strike City

Dear Mr. Van Bremen:

This letter is written in follow-up to a construction storm water inspection I conducted at Strike City located on Windmill Drive in Pickerington, Ohio on July 17, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The majority of the site construction is now complete. Perimeter controls must be maintained specifically on the borders where barren areas remain.
- Final stabilization of the site and/or temporary measures must be implemented within fourteen (14) days from receipt of this letter.

Post Construction Requirements:

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements are found at: [Http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html](http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Craig Van Bremen
Berry and Miller Construction
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Strike city, July 17, 2009