



\*4GC0306020090820\*

2009/08/20

4GC03060

SULLIVANT AVENUE FRIENDS CHURCH



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 20, 2009

Jon Pulcheon  
George J. Igel and Company, Incorporated  
2040 Alum Creek Drive  
Columbus, OH 43207

**Re: Storm Water Inspection at Sullivant Avenue Friends Church  
Franklin County  
Permit #: 4GC03060\*AG**

Dear Mr. Pulcheon:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Heather Nichols, of the Ohio EPA, at Sullivant Avenue Friends Church located at 3030 Clime Road on July 30, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- Upon inspection, it appeared perimeter silt fence was functioning as intended. Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

**Post Construction Requirements:**

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Jon Pulcheon  
George J. Igel and Company, Incorporated  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Sullivant Avenue Friends Church 7-30-09