



4GC0288120090820

2009/08/20

4GC02881

TRI TOWNSHIP FIRE STATION



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 20, 2009

James Page
Page Engineering Inc.
112 E Fifth Street
PO Box 394
Marysville, OH 43040

Re: Storm Water Inspection at Tri Township Fire Station/Permit #4GC02881*AG

Dear Mr. Page:

This letter is written in follow-up to a construction storm water inspection by Ryan Griffin and Rachelle Howe, of the Ohio EPA, at Tri Township Fire Station located on Coover Road in Delaware County on July 22, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- The site appeared to be under active construction. However, be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The sediment basin and silt fence on site appear to be installed and functioning as intended. Sediment and erosion controls must be maintained and fully functional until vegetation is established sufficient to control erosion, which is measured by a minimum vegetative density of 70 percent.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



James Page
Page Engineering Inc
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Tri Township Fire Station 7-22-09