



4GC0296820090820

2009/08/20

4GC02968

4400 NORTH HIGH STREET



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 20, 2009

Tim Rollins
Henderson Partners LLC
150 East Broad Street, Suite 100
Columbus, OH 43215

**Re: Storm Water Inspection at 4400 North High Street / Franklin County
Permit #: 4GC02968*AG**

Dear Mr. Rollins:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at 4400 North High Street located at 4400 North High Street on August 5, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- It appeared that the perimeter silt fence was functioning as intended. Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm 4400 N. High St. 8-5-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



