



\*4GC0267420090820\*

2009/08/20

4GC02674

NORTH UNION MIDDLE SCHOOL



State of Ohio Environmental Protection Agency

RECIPIENT ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3776 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 20, 2009

Scott W. Maruniak  
North Union Local School District  
12920 OH-739  
Richwood, OH 43344

**Re: Storm Water Inspection at North Union Middle School/Permit #4GC02674\*AG**

Dear Mr. Maruniak:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at North Union Middle School located at Grove Street and Mulvane Road in Union County on July 28, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- It was apparent the site was seeded. Please ensure appropriate vegetative density is attained measure by a minimum cover of 70 percent.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm North Union Middle School 7-28-09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



