



\*4GC0216620090813\*

2009/08/13

4GC02166

SOUTH HIGH SCHOOL



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 13, 2009

Tom Sisterhen  
Smoot Elford Resources  
1907 Leonard Avenue  
Columbus, OH 43218

**Re: Storm Water Inspection at South High School/Permit #4GC02166\*AG**

Dear Mr. Sisterhen:

This letter is written in follow-up to a construction storm water inspection by Ryan Griffin and Rachelle Howe, of the Ohio EPA, at South High School located at Ann Street and Stewart Avenue in Franklin County on July 20, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- The silt fence implemented on this site will require maintenance to ensure a proper functioning condition.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm South High School 7-20-09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



