



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE (614) 728-3776 FAX (614) 728-3896
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43215-1049

August 13, 2009

Chris Setzer
Ohio Wesleyan University
61 S Sandusky Street
Delaware, OH 43015

Re: Storm Water Inspection at Ohio Wesleyan University Meek Aquatics & Recreation Center/Permit #4GC03035*AG

Dear Mr. Setzer:

This letter is written in follow-up to a construction storm water inspection by Ryan Griffin and Rachelle Howe, of the Ohio EPA, at Meek Aquatics and Recreation Center located at 150 South Henry Street in Delaware County on July 22, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- The silt fence on site is not entrenched (See Photo Figure 1). The silt fence must be entrenched to prevent sediment-laden water from bypassing the fence and exiting the site.
- A segment of silt fence was installed in front of the inlet to the ditch (See Photo Figure 2). Please maintain this structure and ensure it is adequate to minimize sediment from flowing off-site.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

Chris Setzer
Ohio Wesleyan University
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm: Ohio West Univ Meek Aquatics Center 7-22-09