



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 726-3776 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 13, 2009

Deb Walsh
Thirty-One Company
180 Commerce Boulevard
Johnstown, OH 43031

**Re: Storm Water Inspection at Thirty-One Company
Permit #: 4GC03024*AG**

Dear Ms. Walsh:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Clarissa Lawlis, of the Ohio EPA, at Thirty-One Company located on Commerce Boulevard in Johnstown on July 27, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The sediment basin and perimeter controls for this site appear to be functioning as intended. Please be aware the general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches to ensure continued effectiveness of the sediment basin.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



Deb Walsh
Thirty-One Company
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Thirty-One July 27, 2009