



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

August 13, 2009

Mike Brobst  
Stoneworks Development Co, LLC  
2052 Cherry Valley Road  
Newark, OH 43055

**Re: Storm Water Inspection at the Village of Colonial Woods, Phase I and II  
Permit #4GC01894\*AG**

Dear Mr. Brobst:

This letter is written in follow-up to a construction storm water inspection by Ryan Griffin and Rachelle Howe, of the Ohio EPA, at The Village of Colonial Woods Phase I and II located at 11899 Upper Gilchrist Road in Knox County on July 21, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- Vegetative density is insufficient to protect against erosion (See Photo Figure 1). Please take corrective measures to achieve the required 70 percent vegetative density.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,


Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Village of colonial woods 7-21-09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



**Village of Colonial Woods  
Kokosing River Watershed  
Photo By: Rachelle Howe  
7/21/2009**



**Figure 1**

