



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3896
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 13, 2009

Tom Gabalski
Liebert Services Emerson Network Power
610 Executive Campus Drive
Westerville, OH 43082

**Re: Storm Water Inspection at Liebert Learning Center / Delaware County
Permit #: 4GC02808*AG**

Dear Mr. Gabalski:

This letter is written in follow up to a construction storm water inspection by Amber Miller, of the Ohio EPA, at Liebert Learning Center located at 530 Westar Boulevard on July 24, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- Upon inspection, it appeared the sediment and erosion controls were functioning as intended. Please be aware that the General Permit indicates that all controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. *A log of inspection must be maintained on site for the agency to review.*
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction n requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Tom Gabalski
Liebert Services Emerson Network Power
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO