



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 13, 2009

Paul Cugini
Cugini Capoccia Builders
155 Green Meadows Drive South
Westerville, OH 43081

**Re: Notice of Violation at Northwoods Commercial Development/Franklin County
Permit #4GC02792*AG**

Dear Mr. Cugini:

This letter is written in follow up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at Northwoods Commercial Development located east of the Northwoods Boulevard and High Street intersection on July 23, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

Sediment and Erosion Controls:

- It was noted that the silt fence protecting the stream has failed in multiple locations, (See Figure 1). Adjacent to the check dams, the silt fence was installed incorrectly as it was not entrenched, (See Figure 2). This has allowed sediment to bypass the fence and exit the site.
- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Due to the large amount of drainage area, (see Figure 3), additional measures, such as straw bales, are expected to support and strengthen the silt fence or demonstrate an approvable alternative.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Paul Cugini
Cugini Capoccia Builders
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Northwoods Commercial Development 7-23-09



Figure 1





Figure 2



Whitwoods Commercial Development
Langley Watershed
View up from silt fence
By: Katie Anderson
3. 2009



Figure 3

