



\*4GC0297920090903\*

2009/09/03

4GC02979

ALDI INC-WHITEHALL



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 7, 2009

Daniel Gavin  
Aldi Incorporated (Ohio)  
P.O. Box 2997  
Springfield, OH 45501

**Re: Storm Water Inspection at Aldi Inc – Whitehall / Franklin County  
Permit #: 4GC02979\*AG**

Dear Mr. Gavin:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Heather Nichols, of the Ohio EPA, at Aldi Inc - Whitehall located at 3831 East Main Street on July 28, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls**

- The perimeter silt fence appeared to be functioning as intended. Please be aware that all perimeter silt fence must be maintained until a vegetative cover is achieved for final stabilization.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

**Post Construction Requirements:**

The General Permit mandates specific water quality treatment for storm water following the completion of construction (See Attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Daniel Gavin  
Aldi Incorporated (Ohio)  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Aldi Inc. Whitehale 7-28-09




Figure 1

