



\*4GC0230920090807\*

2009/08/07

4GC02309

REYNOLDS CROSSING, PHASE 1



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778, FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 7, 2009

Jon Kletrovetz  
Dominion Homes  
5000 Tuttle Crossing Boulevard  
Dublin, OH 43016

**Re: Storm Water Inspection at Reynolds Crossing, Phase 1 / Franklin County  
Permit #: 4GC02309\*AG**

Dear Mr. Kletrovetz:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at Reynolds Crossing Phase 1 located on Sandrala Drive in Reynoldsburg, Ohio on July 21, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls**

- It appeared that there was no current construction at the site. Sediment and erosion controls must be maintained and fully fictional until vegetation is established sufficient to control erosion, which is measured by a minimum vegetative density of 70 percent.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Jon Kletrovetz  
Dominion Homes  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Reynolds Crossing Phase 1