



\*4GC0260220090806\*

2009/08/06

4GC02602

NEW ALBANY OHIO STAKE CENTER



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 6, 2009

Bill Glover  
Columbus Ohio FM Group  
P.O. Box 1550  
Dublin, OH 43017

**Re: Storm Water Inspection at New Albany Ohio Stake Center  
Permit #4GC02602\*AG**

Dear Mr. Glover:

This letter is written in follow-up to a construction storm water inspection by Sean Tyler of the Ohio EPA, at New Albany Ohio Stake Center located at 5835 Central College Road in Columbus, Ohio on July 21, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- The perimeter silt fence does not encompass the entire site. The problem area is on the west side of the site. Please install additional silt fence in this area (See Figures 1 and 2).
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. Please to continue to log these inspections.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Bill Glover  
Columbus Ohio FM Group  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO