



4GC0262420090805

2009/08/05

4GC02624

INTERNATIONAL COLLISION REPAIR



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

W. W. Rouse Rorer Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3773 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 5, 2009

Dave Ciolek
International Collision Repair
775 Kaderly Drive
Columbus, OH 43228

**Re: Notice of Termination Inspection at International Collision Repair
Permit # 4GC02781*AG**

Dear Mr. Ciolek:

This letter is written in follow-up to a construction storm water inspection by Sean Tyler of the Ohio EPA, we conducted at International Collision Repair located at 5581 West Broad Street on July 21, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared that construction activity has been completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.html>.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Dave Ciolek
International Collision Repair
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Handwritten signature of Harry Kallipolitis, with the initials "HK" written to the right of the signature.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm International Collision Repair, 7-21-09