



4GC0210720090805

2009/08/05

4GC02107

SPRING CREEK SECT 3 SUBDIVISION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 5, 2009

Kevin Strait
S H & R Limited
8868 Golden Leaf Court
Pickerington, OH 43147

**Re: Storm Water Inspection at Spring Creek Section 3 Subdivision
(Peyton Ridge) / Fairfield County
Permit #: 4GC02107*AG**

Dear Mr. Strait:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Heather Nichols, of the Ohio EPA, at Spring Creek Section 3 Subdivision (Peyton Ridge) located on Cameron Court on July 9, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- It appeared that the sediment controls were functioning as intended. Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Please clear the inlet protections indicated in Figures 1 and 2 to allow for proper drainage.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. The areas noted in Figure 3 will require additional erosion control measures. Please ensure that these areas have at least 70 percent vegetative cover. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Kevin Strait
S H & R Limited
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is written in a cursive style with some initials at the end.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO


HK/nsm Spring Creek Sect 3 Subdivision (Peyton Ridge) 7-9-09



Figure 1



Figure 2



Spring Creek Sect 3 Subdivision
(Payton Ridge)
Sycamore Creek Watershed
Photo by Amber Miller
July 9, 2009



Figure 3: Barren areas

