



\*4GC0214820090903\*

2009/09/03

4GC02148

BRIGGS ROAD FILL AREA



State of Ohio Environmental Protection Agency

RECEIVED ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 5, 2009

Dusty Wilson  
Shelly & Sands, Incorporated  
1515 Harmon Avenue  
Columbus, OH 43216

**Re: Storm Water Inspection at Briggs Road Fill Area / Franklin County  
Permit #: 4GC02148\*AG**

Dear Mr. Wilson:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at Briggs Road Fill Area located at 3303 Briggs Road on July 21, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven-days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This directly applies to the areas noted in Figure 001.

**Post Construction Requirements:**

- The General Permit mandates specific water quality treatment for storm water following the completion of construction (See Attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Dusty Wilson  
Shelly & Sands, Incorporated  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,




Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Briggs Road 7-21-09



Eriggs Road Fill Area  
Scotts River Watershed  
Photos by Amber Miller  
July 21, 2009

Figure 1

