



4GC0243120090807

2009/08/07

4GC02431

ASHVILLE MIDDLE SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 5, 2009

Jeff Sheets
Teays Valley Local School District
385 Circleville Avenue
Ashville, OH 43103

**Re: Storm Water Inspection at Ashville Middle School / Pickaway County
Permit #: 4GC02431*AG**

Dear Mr. Sheets:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at Ashville Middle School located Northeast of State Route 752 and Ashville Pike on July 22, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls

- Storm water staff met with Chris Michael, Project Superintendent. It appeared that construction is near completion. The sediment pond and perimeter silt fence were functioning as intended.
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Jeff Sheets
Teays Valley Local School District
Page -2-

Post Construction Requirements:

- The General Permit mandates specific water quality treatment for storm water following the completion of construction (See Attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at harry.kallipolitis@epa.state.oh.us.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO