



\*4GC0298720090805\*

2009/08/05

4GC02987

LIC-C.R. 42-1.75 PID 78777 PID - 78777



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 726-3778 FAX: (614) 726-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 5, 2009

Naseem Ahmad  
ODOT District Five  
9600 Jacksontown Road  
Jacksontown, OH 43030

**Re: Storm Water Inspections at County Road 42 Improvement Project LIC-  
C.R. 42-1.75 PID 78777 PID -78777/ 4GC02987\*AG**

Dear Mr. Ahmad:

This letter is written regarding a storm water inspection I conducted at the ODOT US 40 & County Road 42 Project in Licking County, on July 9, 2009. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection, the following items were noted:

**Sediment and Erosion Controls:**

- A series of check dams are currently installed approximately 25 feet to 50 feet apart to minimize off-site sedimentation. Please ensure all check dams are properly entrenched into the ground four to six inches and supported with straw bales to increase effectiveness.
- The majority of the perimeter silt fence is inappropriately installed due to its current location. However, there were sections of silt fence that were correctly installed. Please ensure the continued placement of silt fence is installed in a manner in which it will receive drainage to minimize the potential impact to the tributary to the south fork of the Licking River.

**In-Stream Work:**

- Currently there is in-stream work associated with the tributary to the south fork of the Licking River. Please ensure appropriate sediment controls are maintained and reinstalled on a nightly basis if necessary, or in preparation of the next rain event, to ensure compliance with the General Permit.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



**Post Construction Requirements:**

- The General Permit mandates specific water quality treatment for storm water following the completion of construction (See Attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO