



4GC0273620090803

2009/08/03

4GC02736

LONDON CHURCH OF CHRIST



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 3, 2009

Reverend Wendell Hurley
London Church of Christ
316 Harrington Drive
London, OH 43140

Re: London Church of Christ / Madison County

Dear Reverend Hurley:

This letter is written in follow-up to a construction storm water inspection that I conducted at the London Church of Christ located on Westmoor Drive in London, Ohio, on July 29, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- It appeared the basin area has been seeding. Please continue to ensure that an appropriate vegetative density is maintained. No erosion appeared to be leaving the site.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm London church of Christ, July 29, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



