



\*4GC0237120090803\*

2009/08/03

4GC02371

EDINBURGH COVE III



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 3, 2009

Kenneth L. Koppes  
Edinburgh Cove LTD  
1038 Edinburg Cove  
London, OH 43140

**Re: Edinburgh Cove II & III / Madison County**

Dear Mr. Koppes:

This letter is written in follow-up to a construction storm water inspection that I conducted at Edinburgh Cove III located at the end of Wesley Drive in Madison County on July 29, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- The construction entrance still requires stabilization to minimize off-site vehicle tracking.
- The silt fence on site requires maintenance to ensure proper functioning. Please be aware that silt fencing and other erosion controls are required to be inspected weekly or after a significant rain event. Please see attached pictures.
- A large part of the site needs to be stabilized. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This specifically applies to the dirt piles on site. Please see attached pictures.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,


Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Edinburgh Cove III, July 29, 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director







Edinburgh Cove III  
Stabilize barren areas  
Deer Creek Watershed  
July 29, 2009  
Photo by: Greg Sanders



Edinburgh Cove III  
Stabilize barren areas  
Deer Creek Watershed  
July 29, 2009  
Photo by: Greg Sanders





Edinburgh Cove III  
Stabilize barren areas  
Repair/install silt fence  
Deer Creek Watershed  
July 29, 2009  
Photo by: Greg Sanders



Edinburgh Cove III  
Repair silt fence  
Deer Creek Watershed  
July 29, 2009  
Photo by: Greg Sanders

