



4GC0239520090803

2009/08/03

4GC02395

AMHERST MEADOWS SECTION 7 PHASE 2



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 3, 2009

Sovereign Development Corporation
1032 Amherst Boulevard
London, OH 43140

Re: Amherst Meadows / Madison County

To Whom It May Concern:

This letter is written regarding the storm water inspection I conducted, on July 29, 2009, of the construction activities at Amherst Meadows located in London, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. It did not appear that there was any active construction taking place during the time of my inspection. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

Sediment and Erosion Controls:

- Please be aware that if construction activity commences, that the permit requires that all barren areas which remain idle in excess of 21 days must be protected from erosion.

Post Construction Controls:

- You General Permit specifically requires post construction storm water controls for this site. Based on my site observations, it appears that this condition has not been met. Please verify that the post construction requirements will be met (See Attachment).

If you have any questions regarding the contents of this letter, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office.

c: Jeff Bohne Water Quality Supervisor, DSW/CDO

GS/nm Amherst Meadows, July 29, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



