



4GC0276820090930

2009/09/30

4GC02768

BREMEN ELEMENTARY SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 30, 2009

Jim Herd
Fairfield Union Local Schools
7698 Main Street
West Rushville, OH 43163

Re: Bremen ES / Fairfield County

Dear Mr. Herd:

This letter is written in follow up to a construction storm water inspection that I conducted at the Bremen Elementary School located at 210 Strayer Avenue in Bremen, Ohio on September 28, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Barren Areas: 21 Day Rule:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. See attached pictures.

Maintenance:

- The perimeter sediment controls implemented on this site will require reinstallation to ensure a proper functioning condition. See attached pictures. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Post Construction Requirements:


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at greg.sanders@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Jim Herd
Fairfield Union Local Schools
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,




Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosures

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO


GSnsm Bremen ES, September 28, 2009

Bremen ES
Install silt fence
Stabilize barren areas
Rush Creek Watershed
September 28, 2009
Photo by: Greg Sanders



Bremen ES
Install silt fence
Stabilize barren areas
Rush Creek Watershed
September 28, 2009
Photo by: Greg Sanders





Bremen ES
Install silt fence
Stabilize barren areas
Rush Creek Watershed
September 28, 2009
Photo by: Greg Sanders



Bremen ES
Install silt fence
Stabilize barren areas
Rush Creek Watershed
September 28, 2009
Photo by: Greg Sanders



