



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 12, 2011

RE: WAYNE COUNTY
VILLAGE OF DOYLESTOWN
NPDES# 3PB00014

Mayor Terry Lindeman
Village of Doylestown
24 South Portage Street
Doylestown, OH 44230

Dear Mayor Lindeman:

On July 7, 2011, this writer met with Mr. Randy Danford to conduct an inspection of the sewage treatment plant for the Village of Doylestown. The intent of the inspection was to evaluate operations and maintenance of the treatment system.

The wastewater treatment system consists of a raw influent flume, muffin monster comminutor, bar screening, two flow equalization tanks, primary clarifier/digester unit, aerated digester, trickling filter, contact aeration tank, upflow clarifier, RBC units, chlorination/dechlorination.

At the time of the inspection, the treatment system was producing a clear effluent that appeared to be of satisfactory quality. The WWTP plant was in good operation and maintenance condition.

A review of your Discharge Monitoring Reports (DMRs) covering the period January 2011 through May 2011 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2011	001	Nitrogen, Ammonia (NH3	30D Conc	1.5	8.66909	5/1/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	9.106	5/1/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	8.804	5/8/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	8.992	5/15/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	8.002	5/22/2011
May 2011	001	Nitrogen, Ammonia (NH3	30D Qty	2.8	20.6493	5/1/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Qty	4.2	23.3343	5/1/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Qty	4.2	16.8633	5/8/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Qty	4.2	22.2382	5/15/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Qty	4.2	21.4312	5/22/2011

Mayor Terry Lindeman
Village of Doylestown
July 12, 2011
Page 2

Overall the results of this inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

cc: Wayne County Health Dept.
Randy Danford, Public Utility Manager, Village of Doylestown

File: Public/Doylestown/PC