



**Environmental
Protection Agency**

Ted Strickland, Governor
Les Fisher, Lt. Governor
Chris Konecki, Director

May 24, 2010

RE: VILLAGE OF BREWSTER WWTP
NPDES 3PB00006
2010 CEI

Mayor and Council
Village of Brewster
302 South Wabash
Brewster, OH 44613

Dear Mayor and Council:

On May 19, 2010, this office conducted a compliance evaluation inspection (CEI) of The Village of Brewster Wastewater Treatment Plant (WWTP). Present during the inspection were Dean Stoll and this writer from Ohio EPA and Mike Maybaugh, Superintendent, Village of Brewster WWTP.

At the time of the inspection, the treatment system was producing a clear effluent that appeared to be of satisfactory quality.

The mixed liquor in the aeration tank had a good color. The contents of the chlorine contact tank were clear.

A review of your Discharge Monitoring Reports (DMRs) covering the period July 2008 through May 2010 revealed the following effluent violations:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.36	8/1/2008
001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.0555	7/1/2008
001	00665	Phosphorus, Total (P)	7D Conc	1.5	1.55	7/15/2008
001	50060	Chlorine, Total Residu	1D Conc	0.038	.36	7/29/2009
001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.36	9/1/2009
001	00665	Phosphorus, Total (P)	30D Qty	2.5	2.87236	9/1/2009
001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.52	11/1/2009
001	00665	Phosphorus, Total (P)	7D Conc	1.5	1.52	11/8/2009
001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.18	6/1/2009

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

cc: Mike Maybaugh, Brewster WWTP
Steve Hartman, Administrator, Village of Brewster

File: Public/Permit Compliance

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov