



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3896
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 28, 2009

Craig Van Bremen
Berry & Miller Construction
42 Hill Road South
Pickerington, OH 43147

Re: Volunteer Energy / Fairfield County

Dear Mr. Van Bremen:

This letter is written in follow-up to a construction storm water inspection that I conducted at Volunteer Energy located along Windmill Drive, in Pickerington, Ohio, on September 24, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.

There was construction activity at the site during the inspection. The site was stabilized and no erosion was leaving the site. Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Brenda VanCleave, City of Pickerington

GS/nsm Volunteer Energy, September 24, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer

