



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Wazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 28, 2009

Floyd E. Wicks
Rockmill Development Corp.
4920 E. Fifth Ave.
Columbus, OH 43219

Dear Mr. Wicks:

This letter is written regarding storm water inspection I conducted of the construction activities at Misty Meadows, located in Fairfield County, on September 21, 2009. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

There only appeared to be one home under construction during the time of the inspection. The site was stabilized and no erosion was leaving the site. Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

Please install a concrete wash out containment pit on-site and alert the concrete haulers of its location. I did not note any concrete wash pits on-site.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GS/nsm Misty Meadows, September 21, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

