



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 25, 2009

David Dryden  
Greenfield Development Company  
6150 East Broad Street  
Columbus, OH 43213

**Re: Mount Carmel Health System / Fairfield County**

Dear Mr. Dryden:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Mount Carmel Health System and Fairfield Medical Center located at the intersection of Diley Road and Eichhorn Road on September 17, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- Upon inspection, it appeared that the sediment pond and perimeter silt fence were functioning as intended. No erosion appeared to be leaving the site. You appeared to be in compliance with your General Permit.
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

David Dryden  
Greenfield Development Company  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate -  
to contact me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO  
John Lively, Elford Inc. Construction Services  
Randy Duncan, Elford Inc. Construction Services  
Mike Mounts, Elford Inc. Construction Services  
James Aikens, EMH&T