



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 24, 2009

David White
Site Solutions Contractors
38 East Columbus Street
Pickerington, OH 43147

Re: Site Solutions Corporate Office / Fairfield County

Dear Mr. White:

This letter is written regarding the storm water inspection I conducted on September 14, 2009, of the construction activities at the Site Solutions Corporate Office located in the southwestern corner of Pickerington Road and US 33, in Pickerington, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

Silt fencing was installed around the perimeter of the site, but was in need of repair in several areas. The silt fencing must be repaired immediately. Please be aware that the silt fencing must be inspected weekly or after a significant rain event. Logs of the weekly inspections must be kept on-site and made available to Agency staff. Please see attached pictures.

The sediment basin is full of vegetation, i.e., cattails. The vegetation must be removed from the sediment basin. Please see attached picture.

Although the site did not appear to be idle, there were areas that appeared to be at final grade. Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days or areas that are at final grade be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

GLS/nsm Site Solutions Corporate Office,
September 14, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director






Site Solutions Corporate Office
Repair silt fence
Walnut Creek Watershed
September 14, 2009
Photo by: Greg Sanders



Site Solutions Corporate Office
Stabilize barren areas
Walnut Creek Watershed
September 14, 2009
Photo by: Greg Sanders





Site Solutions Corporate Office
Remove vegetation from sediment pond
Walnut Creek Watershed
September 14, 2009
Photo by: Greg Sanders



