

2010/02/02

4GC03074

GOWDY III

\*4GC0307420100202\*





State of Ohio Environmental Protection Agency

RECEIVED ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

February 2, 2010

Todd Sloan  
Partners III LLC  
1533 Lake Shore Drive  
Columbus, OH 43204

**Re: Storm Water Inspection at Gowdy III / Franklin County  
Permit #: 4GC03074\*AG**

Dear Mr. Sloan:

This letter is written in follow-up to a construction storm water I conducted, at Gowdy III located at the southwest corner of Olentangy River Road and Third Avenue intersection on January 28, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- Perimeter controls must be maintained as recent rain events have jeopardized the intended function
- All controls must be maintained via your self-inspection reports every seven days or within 24 hours of a rain event greater than or equal to 0.5 inches. All inspections and corrective actions must be logged and available for review.
- All fill slopes are eroding and must be protected with a temporary cover such as a crimped straw mulch or equivalent.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. All corrective actions must be completed within seven days from receipt of this letter.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Gowdy III 9-9-09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

