



4GC0308320100202

2010/02/02

4GC03083

NEW SUMMIT RD HIGH AND ELEMENTARY SCHOOL



State of Ohio Environmental Protection Agency

RECEIVED ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 2, 2010

Ron Strussion
Reynoldsburg City Schools
7244 East Main Street
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School
Permit #4GC03083*AG, January 29, 2010**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on January 29, 2010. During the inspection, the following items were evaluated: Please note the items below were addressed in my prior storm water inspection on December 31, 2010.

Sediment and Erosion Controls:

- Additional crimped straw mulch is expected for remaining barren areas in preparation for the remaining winter months. This specifically applies to the barren areas east of the stream running through the site. I did note minor earth disturbing activity in the areas east of the stream.
- Please continue to protect the infiltration island associated with site construction. If sediment enters the areas designed for infiltration, the media may have to be replaced
- Erosion protection is expected for the large regional impoundment located on the south west corner of the site.
- At this time, I am formally requesting additional information regarding the final discharge point to waters of the state associated with the southwestern impoundment. The Storm Water Pollution Prevention Plan (SWPPP) was unclear regarding the point of discharge to waters of the state.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ron Strussion
Reynoldsburg City Schools
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Kevin Ballog, Smoot Construction

HK/nsm Summit road High School, 1-29-10