



4GC0308320100429

2010/04/29

4GC03083

NEW SUMMIT RD HIGH AND ELEMENTARY SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TEL: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

April 29, 2010

Ron Strussion
Reynoldsburg City Schools
7244 East Main Street
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School
Permit 4GC03083* AG, April 16, 2010**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on April 16, 2010. The purpose of the inspection was to evaluate compliance with your General Storm Water Permit. During the inspection the following items were evaluated:

Sediment and Erosion Controls:

- It appears less than 20% of the site was protected from erosion with a straw mulch cover, specifically the south central position of the site. Significant areas, specifically east of the stream were not protected as earlier requested.
- Please demonstrate the temporary stabilization requirements of the General Permit have not been violated with the submittal of your inspection reports.
- The large regional sediment basin located on the southwest corner of the site must be stabilized. This issue was brought to your attention during October of 2009 and again during the March 2010 inspection. Corrective actions are expected within seven days from receipt of this letter.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c. Kevin Ballog, Smoot Construction

HK/nsm Summit Reynoldsburg March 18, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



