



\*4GC0128420100429\*

2010/04/29

4GC01284

PROLOGIS PARK 70



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH, 43216-1049

April 29, 2010

Blake Kelly  
Prologis  
3765 Interchange Road  
Columbus, OH 43204

**Re: Storm Water Inspections / Meeting at Prologis**

Dear Mr. Marsh:

This letter is written regarding the storm water inspection I conducted at Prologis located in Licking County on April 14, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment Controls and Erosion Controls:**

- I noted vast areas where storm water was contained within the current excavation. Any dewatering of these areas must be directed to the ponds intended for sediment control
- Site has been stabilized with a temporary cover which must be evaluated via your self-inspection reports. I expected that additional mulch cover will be necessary to ensure effective erosion controls through the upcoming winter months.
- All sediment ponds and outlet structures must be inspected to ensure the intended function.
- Please understand the general permit mandates self inspections of the site, every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, DSW/CDO

HK/nsm Prologis 04-14-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

