



\*4GC0318920100426\*

2010/04/26

4GC03189

STARGATE COLUMBUS



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

April 26, 2010

Michael G. Smith  
Stellar Group, Inc.  
2900 Hartley Road  
Jacksonville, FL 32257

**Re: Stargate Columbus Franklin County**

Dear Mr. Smith:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Stargate Columbus, located at 2842 Spiegel Drive, on April 20, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

I noted that it was possible for storm water to discharge sediment off-site by a storm water pipe located at the construction entrance. I discussed the situation with Mr. Stover, of Stover and Turner Excavation, and he stated that he would install a bulkhead and the storm water pipe where it goes under the construction entrance. Please see attached picture. This appears that it will correct the situation.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO  
Mr. Stover, Stover and Turner Excavation

GS/nsm Stargate Columbus, April 20, 2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Sergeant Colmanus  
Installed Outboard in Block from  
Big Walnut Creek Watershed  
April 20, 2013  
Photo by Greg Sanders



