



4GC0294320100421

2010/04/21

4GC02943

ANCHOR RECYCLING



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 21, 2010

Steven Legg
Anchor Cardinal Park Development LLC
8 E. Long Street, 3rd Floor
Columbus, OH 43215

Re: Storm Water Inspection at Anchor Recycling/Permit # 4GC02961*AG

Dear Mr. Legg:

This letter is written regarding the storm water inspection I conducted at Anchor Recycling, located in Franklin County, on March 25, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

18-Acre Tract

- The centralized sediment basin for the 18-acre tract has not been completed in accordance with the approved Storm Water Pollution Prevention Plan (SWPPP). Concurrent with my last inspection in August of 2009, I was made aware the amount of fill necessary to complete the sediment basin for the site. I was ensured that temporary grading control measures would be maintained at all times concurrent with the fill operation to ensure positive drainage to the trap intended for sediment control.
- The current temporary grading measures are un-satisfactory. Corrective measures must be implemented to installed the sediment basin and storm water controls in accordance with the approved SWPPP **within 30 days from receipt of this letter**
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

48-Acre Tract

- Please continue to maintain positive drainage to the large regional basin located at the western portion of the project. Grading measures must be considered at all times to ensure positive drainage to this impoundment concurrent with the operations at this site. This specifically applies to the disturbed area adjacent to the entrance to the site towards the south.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Steven Legg
Anchor Cardinal Park Development LLC
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Anchor Recycling March 25, 2010