



4GC0312920100421

2010/04/21

4GC03129

ETNA PARKWAY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Cazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 21, 2010

Jerry Berms
Licking County
20 South Second Street
Newark, OH 43055

Re: NOTICE OF VIOLATION: Etna Parkway 4GC00548*AG

Dear Mr. Berms:

This letter is written in follow-up to a construction storm water inspection I conducted at Etna Parkway on April 5 and 7, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities north of Refugee Road.

Sediment and Erosion Control:

- The intersection of Broad Street and Etna Parkway was protected from erosion with a mulch cover. However, due to recent rain events, additional cover is expected.
- All sediment basins have been eliminated due to excess sedimentation. At this time, I am requesting the installation of the sediment basins, addressing the sediment storage requirements in the General Permit. Failure to maintain controls is a direct violation of your General Permit. Submit to my attention a corrective action plan within seven days from receipt of this letter. The corrective action plan must address full implementation of all basins within three days.
- It appears that approximately 90 percent of the site was NOT protected from erosion as previously requested. There are several areas of active erosion as a result. Failure to ensure proper winter stabilization is a direct violation of the permit. Corrective measures are within two weeks from receipt of this letter.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Jerry Berms
Licking County
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

HK/Insm Etna Parkway 04-05-2010