



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 20, 2010

Lewis Stemen
Pickerington Local School District
777 Long Road
Pickerington, OH 43147

**Re: Storm Water Inspection at Tollgate Middle School and Elementary School / Fairfield County
Permit #: 4GC024474*AG**

Dear Mr. Stemen:

This letter is written in follow-up to a construction storm water inspection I conducted at Tollgate Middle School and Elementary School located at the intersection of Tollgate Road and Refugee Road on March 22, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- Upon inspection it appeared that most of the disturbed areas have been seeded and mulched and vegetation is becoming well established. Please continue to monitor all erosion control efforts to ensure a successful vegetative stand, sufficient to control erosion.
- A Notice of Termination can be submitted once vegetation is 70 percent established on all affected areas.
- The site currently drains to basin located off Tollgate Road which drains to the east towards Sycamore Creek.

If you have any questions regarding this letter or my inspection, please do not hesitate to call our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Tollgate Middle School & Elementary School 03-22-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



