



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 20, 2010

Todd Valentine
LW Associates Inc.
184 East Main Street
Ashville, OH 43103

Re: Kingston Mound Manor / Pickaway County

Dear Mr. Valentine:

This letter is written in follow up to a construction storm water inspection that I conducted at Kingston Mound Manor located along Kingston Road on April 15, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed or mulch) this specifically applies to barren areas located near the intersection of Whitney Avenue and Adena Trail. These barren areas need to be re-seeded. Please see attached pictures.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Kingston Manor, April 15, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

