



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Blazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 19, 2010

Reverend Wendell Hurley
London Church of Christ
316 Harrington Drive
London, OH 43140

Re: London Church of Christ / Madison County

Dear Reverend Hurley:

This letter is written in follow-up to a construction storm water inspection that I conducted at the London Church of Christ located on Westmoor Drive in London, Ohio, on April 13, 2010. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- There was no active construction at the site. The site was stabilized and no erosion was leaving the site.
- Be aware that if construction activity starts again that the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm London church of Christ, April 13, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

