



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 15, 2010

Sovereign Development Corporation
1032 Amherst Boulevard
London, OH 43140

Re: Amherst Meadows / Madison County

To Whom It May Concern:

This letter is written regarding the storm water inspection I conducted, on April 13, 2010, of the construction activities at Amherst Meadows located in London, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. It did not appear that there was any active construction taking place during the time of my inspection. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

Sediment and Erosion Controls:

- Please be aware that if construction activity commences, that the permit requires that all barren areas which remain idle in excess of 21 days must be protected from erosion. There is a small area near the construction trailer that needs to be stabilized. Please see attached picture.

If you have any questions regarding the contents of this letter, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely


Gregory L. Sanders
Environmental Specialist
Ohio EPA, Division of Surface Water
Central District Office.

Enclosure

c: Jeff Bohne Water Quality Supervisor, Ohio EPA/DSW/CDO

GS/nm Amherst Meadows, April 13, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Amherst Meadows
Stabilize barren areas
Deer Creek Watershed
April 13, 2010
Photo by: Greg Sanders



