



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 14, 2010

Carl Walters
Columbus Department of Public Service and Transportation
90 West Broad Street
Room 301
Columbus, OH 43215

**Re: Storm Water Inspection at Morse Road Improvement Project
Permit Number 4GC02681*AG**

Dear Mr. Walters:

This letter is written regarding the storm water inspection I conducted at Morse Road Improvement Project on March 22, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- The majority of the project had been seeded and mulch. Please monitor these areas to ensure a successful vegetative stand to control erosion
- I have received concerns that the "dandy bags" near the ODNR complex require maintenance. Please ensure all controls are cleaned and maintained. I will conduct a follow up inspection in the upcoming weeks to evaluate compliance.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://epa.ohio.gov/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Carl Walters
Columbus Department of Public Service and Transportation
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Morse Rd improvements March 22, 2010