



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3698
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 12, 2010

Herb Glimcher
150 East Broad Street
Columbus, OH 43215

Re: Orange Corporate Center, Permit Number 4GC02065*AG

Dear Mr. Glimcher:

This letter is written in follow up to a construction storm water inspection I conducted at Orange Center located at the intersection of Orange Road and US Route 23 in Delaware county on March 22, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- The perimeter controls were installed and appeared functioning on this date. Please maintain these controls via your self-inspection reports every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches
- Measures must be implemented to ensure positive drainage from the site to the ponds intended for sediment control. The ponds must be completed with an outlet structure modified to address sediment control within in seven days from receipt of this letter.
- The General Permit mandates all barren areas which remain idle in excess of 21 days must be protected from erosion within 7 days.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm OrangeCenterUSRoute23 03-22-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

